Email: psk@psk.cc Website: www.psk.cc

# GNP - 1 Automatic transfer switch controller

The completely automatic transfer switch monitors incoming voltage from the 3 Phase utility lines, around the clock. When utility power is interrupted, the automatic transfer switch immediately senses the problem and signals the generator to start. Once the generator is running at proper speed, the automatic transfer switch safely shuts off the utility line and simultaneously opens the generator power line from the generator. Within seconds, your generator system begins supplying electricity to the critical emergency circuits of your home or business. The transfer switch senses the utility line voltage has returned at a steady state, it re-transfers the electrical load back to the utility line and resumes monitoring for subsequent utility loss. The entire system stands ready for the next power outage.



#### Features

Supervision three-phase supply lines. Phase sequence and total loss of one or more phase. Loss of neutral line. User controlled delayed transition. 3% Hysteresis insure smooth transfer. Device protected against voltage harmonics

# **Operation Sequence Description**

Corre	ect main supply		
	Operation	Indication	Explanation
	Applied 3 Phase main supply	LED (UM) on	indicates:3 phase main connection on
		LED (NV) on	indicates: Neutral connection on
2	Delay time	(0 – 30sec)	can be adjusted from the front panel
		Main relay RMC energize	supplies 230VAC to mains contactor (CN)
3	At the end of delay interval	Mains LED (R) on	indicates: mains contactor energizes
		Relay Contacts (11)&(9) closed	indicates: generator auto activation is disconnected

# Mains Power failure

Operation		Indication	Explanation
1	Main power failure	Contacts (10) & (9) closed LED indicator (UG) on LED indicator (NV) off LED indicator (UM) off	commands generator on indicates: GNP-1 supplies from generator indicates: main Supply voltage failure indicates: main Supply voltage failure
	Delay timer	(0-30sec)	can be adjusted from the front panel
2	At the end of delay interval	relay RGC energize LED indicator (R) generator on	supplies 230VAC to generator main contactor (CG) indicates "GEN" contactor energizes

# Mains Voltage Restored

	Operation	Indication	Explanation
1	Restored 3 phase main	LED indicator (UM) on LED indicator (NV) on	indicates: 3 phase main connection on indicates: Neutral connection on
2	Delay timer	(0-30sec)	can be adjusted from the front panel
3	At the end of delay interval	Relay (RGC) de-energize	Generator main contactor (CG) de-energize LED indicator (R) generator off LED indicator (UG) off
4	After additional 1sec internal delay		supplies 230VAC to mains contactor (CN) indicates: mains contactor energizes
		Relay Contacts (11)&(9) closed	indicates: generator auto activation is disconnected

#### Indicator lights and Contacts

	Indication	LED Color	Description
	UM	Green	Gnp -1 Receive 3 phase supply from mains
Main	R	Red	Supplied 230VAC to mains contactor (CN)
	NV	Red	Neutral connection on
Generator	UG	Green	Input voltage generator operates
	R	Red	230VAC supplies to generator contactor (CG)
	(11) (10) (9)		Contact outputs to activate / de-activate the generator .
	(NG) (RG)		Generator voltage inputs.
Contacts	(NM) (TM) (SM) (RM)		Mains 3 Phase voltage inputs
	(RMC)		Supply 230VAC to Mains contactor (CM)
	(RGC)	Supply 230VAC to Main Generator contactor (CG)	
Timers	Mains timer		Delay on make (0-30sec) adjustable from the front panel
	Generator timer	Delay on make (0-30sec) adjustable from the front panel	

1

Controllers Ltd





 $\in$ 

# GNP - 1 Automatic transfer switch controller


Technical Data	
Operational Voltage:	3 x 400VAC 50/60Hz
Relays:	1 form C (SPDT)
Switching capacity:	10A /240V COS φ = 1
Rated voltage:	250VAC
Contact rating (resistive load):	10A 250VAC, 6A 30VDC
Max switching Power / current:	1000W 12A
Mechanical life:	1 x 106 ops (at rated load)
Electrical life:	1 : 200,000 ops
Operating Temp:	-20°C+ 55°C
Storage temp:	-25°C+70°C
Transport temperature:	-25°C+70°C
Relative humidity:	15%85%
Case material:	Self-extinguishing plastic housing UL V0 acc IEC 529
Mounted:	on DIN-rail TS 35 according to EN 50022
Mounting position:	vertically
Protection class open air	IP20
Certification & compliance acc to :	EN 61010- 1:2010, IEC 61010-1:2010
Terminal certification:	IEC 60947-7-1, IEC 60998-1
Terminal Capacity:	1x4mm2 without multicore cable end 1x0.5 to 2.5mm2 with/without multicore cable end
Wight:	171 gram


### Schematic connection






# Dimensions






**Protaction Recomended:** C1 1 Pole C curve Circuit Breaker 4A C2 3 Pole C curve Circuit Breaker 4A Controllers Ltd





D I N ~\_\_\_\_\_



# **Precautions For Installation and Safe Use**

Failure to follow those instructions will result in death or serious injury.

- Disconnect all power before working on equipment.
- Do not try to clean the device with solvent or the like. Only clean the device with a dried cloth.
- Verify correct terminal connections when wiring.
- To connect the unit, use appropriate insulated 230VAC cord.
- Electrical equipment should be serviced only by your competent seller.
- Mounted on DIN rail TS 35 according to EN 50022.
- Product intended for installation in electricalcabinets or IC boxes.
- No responsibility is assured by the manufacturer or any of its subsidiaries for any consequences Arising out of the use of this material.



The systems type GNP1/GNP2/GNP-SP are not approved for use in resuscitation facilities, or individual analysis facilities or medical facilities that support human life or stabilizers, such as: emergency rooms, ambulatory rooms, resuscitation rooms, etc. The buyer agrees to notify PSK Controllers Ltd presentation on the use of the products listed in one of the facilities mentioned above. To make it clear, only PSK Controllers Ltd, have the right to decide and determine which product is suitable for use under the requirements uses. If the equipment is used in a manner not specified by the manufacture, the protection provide by the equipment may be impaired.

 $\in$ 

\*It is recommended to install a bypass switch for an emergency event.